

Online Drinking Water Notifications

Local authority: Wexford County Council

Supply name: New Ross Supply code: 3300PUB1589

Population served: 7800 Population affected: 7800

Sample date: 02/05/2012 Sample location: Treated water at Castlemoyle WTW, New Ross

Notification under regulations: 10(2)

Has the HSE been consulted: Yes

HSE contact: John Redmond HSE contact number: 087 6297110

Advice from HSE: Meeting HSE on Thursday May 10th to discuss response

Boil notice:

Date issued: None Date rescinded: None

Boil Notice Parameter: None Boil Notice Precautionary: No

Advisory notice:

Date issued: None Date rescinded: None

Advisory Notice Parameter: None Advisory Notice Precautionary: No

Likely causes: Awaiting Council Investigations

Additional Info.

Immediate action taken to inform/protect consumers: Will await outcome of meeting with HSE

Immediate corrective action taken: Additional sampling for cryptosporidium to be done

Notification date: 09/05/2012

Name: Mr. Paul Delahunty

Email: paul.delahunty@wexfordcoco.ie Phone number: 053 9135046

Parameter	Units	Result	Exceeded In Last 12 Months	Chlorine Levels	Recent Details of Raw Water	Chlorine Monitor Alarm	Chlorine Dosing	Flow Dosing	Dosing linked to Chlorine Residual	Contact Time
Cryptosporidium	per 10L	0.23	False		Details to follow. Recent rain. Previous cryptosporidium					