

Online Drinking Water Notifications

Local authority: Wexford County Council

Supply name: Oulart Supply code: 3300PUB1605

Population served: 90 Population affected: 90

Sample date: 02/05/2012 Sample location: 9 Mayview Park, Oulart

Notification under regulations: 10(2)

Has the HSE been consulted: Yes

HSE contact: John Redmond HSE contact number: 087 6297110

Advice from HSE: None to date

Boil notice:

Date issued: None Date rescinded: None

Boil Notice Parameter: None Boil Notice Precautionary: No

Advisory notice:

Date issued: None Date rescinded: None

Advisory Notice Parameter: None Advisory Notice Precautionary: No

Likely causes: Awaiting Council Investigations

Additional Info: Request was made to the DECLG through our Rural Water Programme Small Public Water & Sewerage Schemes allocation to connect this scheme to the Sow Regional WSS. Unfortunately insufficient funds were allocated in 2012 to undertake this work. This has been appealed to the DECLG.

Immediate action taken to inform/protect consumers: n/a

Immediate corrective action taken: Both sources will be sampled for nitrate to determine which is the contaminated source. Measures will then be taken to rectify the situation

Notification date: 04/05/2012

Name: Mr. Paul Delahunty

Email: paul.delahunty@wexfordcoco.ie Phone number: 053 9135046

Parameter	Units	Result	Exceeded In Last 12 Months	Chlorine Levels	Recent Details of Raw Water	Chlorine Monitor Alarm	Chlorine Dosing	Flow Dosing	Dosing linked to Chlorine Residual	Contact Time
Nitrate	mg/l	76	False		Two Sources, a spring and a borehole.					