

Online Drinking Water Notifications

Local authority: Wexford County Council

Supply name: Castledockrell Supply code: 3300PUB1440

Population served: 80 Population affected: 80

Sample date: 09/05/2012 Sample location: 1 Minerva Park, Castledockrell

Notification under regulations: 10(2)

Has the HSE been consulted: Yes

HSE contact: John Redmond HSE contact number: 087 6297110

Advice from HSE: Get history of nitrate exceedences

Boil notice:

Date issued: None Date rescinded: None

Boil Notice Parameter: None Boil Notice Precautionary: No

Advisory notice:

Date issued: None Date rescinded: None

Advisory Notice Parameter: None Advisory Notice Precautionary: No

Likely causes: Awaiting Council Investigations

Additional Info.

Immediate action taken to inform/protect consumers: n/a

Immediate corrective action taken: Checking history of exceedences. Checking area

Notification date: 16/05/2012

Name: Mr. Paul Delahunty

Email: paul.delahunty@wexfordcoco.ie Phone number: 053 9135046

Parameter	Units	Result	Exceeded In Last 12 Months	Chlorine Levels	Recent Details of Raw Water	Chlorine Monitor Alarm	Chlorine Dosing	Flow Dosing	Dosing linked to Chlorine Residual	Contact Time
Nitrate	mg/l	57.51	False		Water from borehole normally good quality.					