

Online Drinking Water Notifications

Local authority: Wexford County Council

Supply name: Sow Regional Supply code: 3300PUB1641

Population served: 11800 Population affected: 11800

Sample date: 24/04/2012 Sample location: 6 st patricks terrace, Crossabeg

Notification under regulations: 10(2)

Has the HSE been consulted: Yes

HSE contact: John Redmond HSE contact number: 087 6297110

Advice from HSE: The Drinking Water Regs state as follows:
 "In the event of non-compliance with this parametric value, the supply shall be investigated to ensure that there is no potential danger to human health arising from the presence of pathogenic micro-organisms, e.g. cryptosporidium."
 Source investigation is required. Please indicate results of cryptosporidium testing to date.

Boil notice:

Date issued: None Date rescinded: None

Boil Notice Parameter: None Boil Notice Precautionary: No

Advisory notice:

Date issued: None Date rescinded: None

Advisory Notice Parameter: None Advisory Notice Precautionary: No

Likely causes: Awaiting Council Investigations

Additional Info: three cryptosporidium results taken on March 28th, April 4 and 18th on Sow Regional were clear. Awaiting result of sample taken on May 2nd. Clostridium retest done on April 27th was clear

Immediate action taken to inform/protect consumers: n/a

Immediate corrective action taken: Chlorine levels raised from 0.6 to 0.7 in final waters

Notification date: 03/05/2012

Name: Mr. Paul Delahunty

Email: paul.delahunty@wexfordcoco.ie Phone number: 087 622 3204

Parameter	Units	Result	Exceeded In Last 12 Months	Chlorine Levels	Recent Details of Raw Water	Chlorine Monitor Alarm	Chlorine Dosing	Flow Dosing	Dosing linked to Chlorine Residual	Contact Time
Clostridium Perfringens	per 100ml	1	False	Free Chlorine 0.07 Total Chlorine 0.11	Increased rain in river	True	True	True	False	25